

**NOTES FOR NWL ASSEMBLY:**

1. AFTER UNIT IS TESTED, ATTACH FOAM SLEEVE TO BUSHING USING TIE WRAP. SECURE IN 3 PLACES.

2. SECURE BUSHING LABEL TO FOAM SLEEVE BY PLACING TIE WRAP THROUGH LABEL HOLE. LABEL MUST BE ORIENTED SO THAT IT IS READABLE FROM THE OPEN END OF THE SHIPPING BASE.

3. ATTACH TO SHIPPING PALLET, (4) PLACES, WITH  $\frac{3}{8}$  X 2" LONG LAG SCREWS AND  $\frac{3}{8}$ " FLAT WASHERS.


**NOTES FOR END USER:**

1. IF RETURNING A POWER PLUS TANK ASSEMBLY, ALWAYS SHIP IT MOUNTED ON THE SHIPPING BASE PROVIDED WITH THE NEW REPLACEMENT TANK. MOUNT THE TANK/BASE ASSEMBLY TO THE ORIGINAL SHIPPING PALLET WITH  $\frac{3}{8}$  X 2" LONG LAG SCREWS AND WASHERS PROVIDED.

2. IF THE TANK OR BUSHING HAS BEEN DAMAGED AND THE TANK IS LEAKING OIL, THE OIL MUST BE COMPLETELY DRAINED AND THE TANK WIPED DOWN BEFORE SHIPPING. WRAP THE UNIT WITH PLASTIC SHEET IF NECESSARY.

Item	Qty	Name	Note
7	1	122220	SHIPPING PALLET
6	1	M40212	SLEEVE LABEL
5	1	M40211	BUSHING LABEL
4	1	H90427	FOAM SLEEVE
3	1	113416	TANK GASKET
1	1	116800	SHIPPING BASE
Parts List			

REV	DATE	APP BY	DESCRIPTION
A	10/29/08	TDB	ADDED SHIPPING PALLET, REVISED NOTES

 RISING SUN ROAD, BORDENTOWN, N.J. 08505 TEL (609)-298-7300 FAX (609)-298-1982		
<b>TITLE</b> POWERPLUS OIL TANK SHIPPING BASE ASSEMBLY INSTRUCTIONS		
SCALE	APP'D BY	DATE
1=14	RJK	06/08/07
DWG. BY	D.E.	DWG.
CSM	CSM	B125273
TOLERANCES: (UNLESS OTHERWISE SPECIFIED) ANGLES: +/- 5°    DECIMALS: .XX +/- 0.1 FRACTIONS: +/- 3/16    .XXX +/- 0.05		NWL PROPRIETARY INFORMATION, NOT TO BE REPRODUCED WITHOUT WRITTEN CONSENT.